



Saint Paul - Ramsey County Department of Public Health
 Environmental Health Section
 2785 White Bear Avenue North Suite 350
 Maplewood, MN 55109-1320
 FAX: (651) 266-1177

Date: 4-19-11 1:30

To FAX#: 6-8574

FACSIMILE TRANSMISSION
 Cover Sheet and Transmittal Form

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Tim Yannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-7-11

APPEAL PROPERTY ADDRESS: 1732 YORK

APPLICANT NAME: PUBLIC HEALTH (DNR) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: CASERMENT

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 5.4 sqft	DIFFERENCE FROM REQUIRED AREA: COMP.
WIDTH OF OPENING: 17.18	DIFFERENCE FROM REQUIRED OPENING: 2.82"
EIGHT OF OPENING: 40.95	DIFFERENCE FROM REQUIRED OPENING: COMP.
EIGHT OF OPENING TO FINISHED FLOOR: 498"	DIFFERENCE FROM MAXIMUM HEIGHT: COMP.

RECOMMENDATION (IF APPLICABLE): SEE ATTACHMENTS

FROM: _____

Select a Model: 0971

(Model 0971)
Single Vent Casement

Min. W: 16 Max. W: 28
Min. H: 19 Max. H: 78 Max. U/I: 144

Width: 24 Exact Size: 24
Height: 45.325 Exact Size: 45.325

Exclusion: Select Exclusion
Opening: Exact Size
Type: Standard
Screen:
Class: OX44 Strength (3 mm)

AC Sash Calculator

Sash Width	22.3751
Sash Height	43.1000
Egress Width	19.3750
Egress Height	40.1000
Screen Width	19.3750
Screen Height	41.3250
Egress Opening Width (Standard Hinge)	17.7500
Egress Opening Height (Standard Hinge)	40.5500
Egress Opening Area w/Standard Hinge (sq.ft.)	3.6258
Egress Opening Width (Egress Hinge)	17.8750
Egress Opening Height (Egress Hinge)	40.9500
Egress Opening Area w/Egress Hinge (sq.ft.)	4.8317

* $19.375 \times 40.7 = 788.3 \div 144 = 5.4 \text{ sqft}$