



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

APR 17 2015

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number CL# 8647)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

<p>HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>4-28-15</u></p> <p>Time <u>1:30 p.m.</u></p> <p>Location of Hearing: <u>Room 330 City Hall/Courthouse</u></p>
--

Address Being Appealed:

Number & Street: 1692 Race Street City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Jim Hansen Email jmlawiehansen@g.com

Phone Numbers: Business _____ Residence _____ Cell 651-~~800~~³³⁸-5047

Signature: [Signature] Date: 4/17/15

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List/Correction
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other (Fence Variance, Code Compliance, etc.)
- Property is not rental property
Home occupied by father
Father purchased home in 1986
Father pays property taxes + any other city fees
Father's name was removed and put in
Son's name for estate planning purposes



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 8, 2015

JAMES M HANSEN
8265 COLLEGE TRL
INVER GROVE HEIGHTS MN 55076-3243

FIRE INSPECTION CORRECTION NOTICE

RE: 1692 RACE ST
Ref. #112531
Residential Class: B

Dear Property Representative:

Your building was inspected on March 30,, 2015 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made on May 1, 2015 at 9:30 am.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 2nd Floor - Left bedroom - South wall - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.-
2. 2nd Floor - Top of stairway - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate ballustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.-

3. Basement - MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.-REQUIRES LICENSED CONTRACTOR UNDER PERMIT AND INSPECTION BY WARM AIR / VENT INSPECTOR.
CALL JON 266-9062

4. Basement - SPLC 34.11(5), 34.34(2), SPC 4715.0200Q - Provide adequate hot water between 120 degrees F and 130 degrees F.-Hot water 133 F.

5. Basement stairs - SPLC 34.10 (3), 34.33(2) - Repair or replace the damaged guardrail in an approved manner.-

6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: mike.cassidy@ci.stpaul.mn.us or call me at 651-266-8984 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy
Fire Inspector

Reference Number 112531