



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220  
Saint Paul, MN 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-1919  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

361

April 17, 2013

12-085213

Raymond F Vorderbruggen  
6924 105th St W  
Bloomington MN 55438-2183

## Order to Abate Nuisance Building(s)

Dear Sir or Madam:

**The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:**

**1071 SHERBURNE AVE**

With the following Historic Preservation information: NONE

**and legally described as follows, to wit:**

Simonitschs Subdivision of Bl Lot 23 Blk 1

**to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.**

On April 3, 2013 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

**This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.**

This is a two-story, wood frame, single-family dwelling with a detached, one-stall, wood frame garage.

The following is excerpted from the July 20, 2012 Revocation of Fire Certificate of Occupancy and Order to Vacate:

1. GARAGE - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements. REPAIR ALL DAMAGED SURFACES AND REPAINT IN A PROFESSIONAL MANNER. REPLACE BROKEN WINDOW IN GARAGE DOOR.
2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
3. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
4. SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door latch. REAR STORM DOOR NEEDS A LATCH AND HANDLE.
5. SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. PROFESSIONALLY PREPARE AND PAINT ALL EXPOSED WOOD SURFACES ON MAIN BUILDING.
6. SPLC 34.09 (2) 34.32 (2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair. INSTALL HANDRAIL AT FRONT ENTRY DOOR.
7. SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window glass. REPLACE BROKEN OR MISSING GLASS IN BASEMENT WINDOW.
8. SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screen. ALL OPERABLE WINDOWS SHOULD HAVE SCREENS IN PLACE.
9. SPLC 34.19 - Provide access to the inspector to all areas of the building.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **May 17, 2013** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

April 17, 2013  
1071 SHERBURNE AVE  
page 4

If you have any questions or request additional information please contact **Matt Dornfeld** between the hours of 8:00 and 9:30 a.m. at **651-266-1902**, or you may leave a voice mail message.

Sincerely,

Matt Dornfeld  
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council

ota60135 5/11