



APPLICATION FOR APPEAL

RECEIVED

NOV 09 2010

CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>11/16/10</u>
Time <u>1:30</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1761 Lincoln Ave City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 11-03-10

Name of Owner (if other than Appellant): David Gamache

Address (if not Appellant's): 1761 Lincoln Ave

Phone Numbers: Business _____ Residence 651-340-3871 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 double hung replacement windows that will not comply w/ Egress Policy. The current dimensions allow 24" in operable width and 20 3/4" in operable height. Overall glazed area is exceeded by 4.5 sqft. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 2, 2010

APPEAL PROPERTY ADDRESS: 1761 LINCOLN AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 917642
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 2

Total Glazed Area	9.5 sq. ft.	Difference from Required Area	+ 4.5 sq. ft.
Width of Opening	24"	Difference from Required Opening	+ 4 "
Height of Opening	20 3/4"	Difference from Required Opening	- 3 1/4
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.