



# APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

FEB 15 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed *in person*

YOUR HEARING Date and Time:

Tuesday, Feb. 21, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 910 Case Ave City: St Paul State: MN Zip: 55106

Appellant/Applicant: The Window Store Home Emp Email Michelle@homesureinc.com

Phone Numbers: Business 612 353-5780 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: Donk Tanberg <sup>Tanberg</sup> Date: 2-15-12  
6044 Central Ave.  
Fridley, MN 55432


Name of Owner (if other than Appellant): Judy Bollmann

Address (if not Appellant's): 910 Case Ave St Paul MN

Phone Numbers: Business \_\_\_\_\_ Residence 612 797-9861 Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O Needs DH windows for
- Summary/Vehicle Abatement AC units.
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: February 15, 2012

APPEAL PROPERTY ADDRESS: 910 CASE AVE

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 612-353-5780

PERMIT NUMBER: 12 024329

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

<b>Total Glazed Area</b> Minimum 5 Square Feet	3.932 sq. ft.	<b>Difference from Required Area</b>	-1.068 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	23.594"	<b>Difference from Required Opening</b>	+ 3.594"
<b>Height of Opening</b> Minimum 24 Inches	24"	<b>Difference from Required Opening</b>	ok
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	ok	<b>Difference from Maximum Height</b>	ok

COMMENTS:

Reviewed by: DD 2-15-12



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: February 15, 2012

APPEAL PROPERTY ADDRESS: 910 CASE AVE

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 612-353-5780

PERMIT NUMBER: 12 024329

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

<b>Total Glazed Area</b> Minimum 5 Square Feet	3.483 sq. ft.	<b>Difference from Required Area</b>	-1.517 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	31.344"	<b>Difference from Required Opening</b>	+11.344"
<b>Height of Opening</b> Minimum 24 Inches	16"	<b>Difference from Required Opening</b>	-8"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	Ok	<b>Difference from Maximum Height</b>	ok

COMMENTS:

Reviewed by: DD 2-15-12