



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

John Taylor
3625 – 47th St E
Minneapolis, MN 55406

Re: Appeal of Fire Inspection Correction Notice for property at 927 Tuscarora Avenue
File No. ALH 10-526

Dear Mr. Taylor:

This is to confirm that on December 9, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 5-inch variance on the openable height of the egress window in the west second floor bedroom and a 2.5-inch variance on the openable height of the egress window in the east second floor bedroom.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
File