

**Marcia Moermond - 1080 Payne Ave**

---

**From:** Kris Skow-Fiske  
**To:** Moermond, Marcia  
**Date:** 1/26/2012 7:52 AM  
**Subject:** 1080 Payne Ave  
**Attachments:** 100\_2193.jpg; 100\_2189.jpg; 100\_2190.jpg; 100\_2191.jpg; 100\_2192.jpg

---

Mrs. Moermond,

The conversation I had with the owner was recalculating the occupant load to verify if the back exit needed to swing in the way of travel which it is required to swing outward. It also requires panic and I gave him the option of three point panic for more security with no door handle on the exterior.

I have attached pictures of the back exit and they will also be in Amanda.

Thanks,

**Kris Skow-Fiske**

Fire Inspector  
Department of Safety and Inspections  
375 Jackson Street  
St. Paul, MN 55101  
651.266.8949  
651.266.8951 fax