



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 2-3-11

COVER SHEET AND TRANSMISSION FORM
FACSIMILE TRANSMISSION

To FAX#: 6-8574

RECEIVED
FEB 03 2011
CITY CLERK

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St Paul

Sender: Daniel Schmidt / Tim Hanorelly
St Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

Request for Egress Windows Non-Compliance Determination
Attachments: Egress Windows Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-268-8574

DATE: 2-3-11

APPEAL PROPERTY ADDRESS: 1017 Englewood

APPLICANT NAME: RUSIC HEATH (DAMEL) PHONE NUMBER: 651-266-1148

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.75 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 27" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 23.325" DIFFERENCE FROM REQUIRED OPENING: 625"

HEIGHT OF OPENING OF FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

