



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED

AUG 17 2011

CITY CLERK

emailed the date of hearing

1. Address of Property being Appealed: <u>2091 PRINCETON AVE</u>	2. Number of Dwelling Units: <u>1</u>	3. Date of Letter Appealed: <u>8-15-11</u>
---	--	---

4. Name of Owner: BOB SUTHERLAND
 Address: 2091 PRINCETON City: ST PAUL State: MN Zip: 55105
 Phone Numbers: Business _____ Residence 651-699-8567 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): HARMONY HOMES INC.
 Address: 1120 WINTER ST NE City: MPIS State: MN Zip: 55413
 Phone Numbers: Business 612-238-0522 Residence _____ Cellular _____
 Signature: Brian Murray BMURRAY@HARMONYHOMESINC.NET

6 State specifically what is being appealed and why (Use an attachment if necessary):
PERMIT TO INSTALL 1 BEDROOM WINDOW
IT IS THE LARGEST AVAILABLE TO MATCH
EXISTING BUT DID NOT MAKE EGRESS
CODE FOR ST PAUL
BUT DOES COMPLY WITH MN BUILDING CODE
R 300.1.5
THANK YOU

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>8-17-11</u>	Fee Received: <u>25 pd</u>	Receipt Number:	Date of Hearing: <u>9-6-11</u>
----------------------------------	-------------------------------	-----------------	-----------------------------------



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 15, 2011

APPEAL PROPERTY ADDRESS: 2091 PRINCETON AVE
APPLICANT NAME: HARMONY HOMES INC
PHONE NUMBER: 612-238-0522
PERMIT NUMBER: 11 262975
TYPE OF WINDOW Double hung
NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	6.1	Difference from Required Area	ok
Width of Opening Minimum 20 Inches	23 5/16"	Difference from Required Opening	+3 5/16
Height of Opening Minimum 24 Inches	17 13/16"	Difference from Required Opening	-6 13/16
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 8-15-11