



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

NOV 23 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number 337988)
- Copy of the City-issued orders or letter which
are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Dec 7, 2010

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 842 Sherwood Ave City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Dennis Potapenko Email Dennis@northlandhome.net

Phone Numbers: Business (651) 464-0234 Residence (651) 774-3367 Cell _____

Signature: Dennis Potapenko Date: 11/22/10

Name of Owner (if other than Appellant): Doyle Land

Address (if not Appellant's): 308 15th St SW #100 Forest Lake mn 55025

Phone Numbers: Business (651) 464-0234 Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other Egress non-compliance
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 16, 2010

APPEAL PROPERTY ADDRESS: 842 SHERWOOD AVE

APPLICANT NAME: NORTHLAND HOME EXTERIORS

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 792744

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Two

Total Glazed Area	8.0 sq. ft.	Difference from Required Area	+2.3 sq. ft.
Width of Opening	24"	Difference from Required Opening	+4"
Height of Opening	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	

COMMENTS:

St. Paul - Gov Appeals

Reviewed by: David Nelson