



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

361

July 17, 2012

02-100547

Ying Moua/Tia Lee
152 Jessamine Ave E
St Paul MN 55117-5071

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

878 AURORA AVE

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Milton Addition Lot 5 Blk 2

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On April 25, 2012 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one and one-half story, wood frame, single-family dwelling with a detached two-stall wood frame garage.

The following Deficiency List is excerpted from the September 19, 2011 Code Compliance Report.

BUILDING **Inspector: Jim Seeger** **Phone: 651-266-9046**

- Install 20 minute fire rated doors, with self closing device, between common areas and individual units. All penetrations required to have property intumescent device or caulk (per current building codes).
- Maintain one hour fire separation between dwelling units and between units and common areas.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Repair walls, ceiling and floors throughout, as necessary.
- Provide fire block construction as necessary and seal chases in basement ceiling.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Co Conservation Code and the MN Dept. of Labor and Industry.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Install rain leaders to direct drainage away from foundation.
- Provide general rehabilitation of garage and properly repair siding to code at grade.
- Install address numbers visible from street and on the alley side of garage.
- Review all applicable codes & policies when replacing windows including egress windows for sleeping rooms.
- Properly install drip cap or flashing on all exterior openings, doors, windows etc., both on house and garage.
- Front porch siding needs flashing on window and door openings.
- Install vapor barrier in crawl space.
- Install 1 hour fire wall on west side of garage , whole wall from roof deck to floor.
- Install guardrail and handrail on basement stairs.
- A building permit is required to correct the above deficiencies.

ELECTRICAL **Inspector: Dan Moynihan** **Phone: 651-266-9036**

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits
- Verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Close openings in service panel/junction box with knock out seals, breaker blanks and/or junction boxes

- Install/replace GFCI receptacle in first and second floor bathroom adjacent to the sink
- Install globe-type enclosed light fixture on all closet lights
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Install exterior lights at front/side/back door
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement/garage
- Upgraded services, wire and ground 10 2001 NEC.
- Purchase a permit for a service and 18 circuits.
- Properly wire boilers.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).

ELECTRICAL Inspector: Dan Moynihan Phone: 651-266-9036

- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING Inspector: Rick Jacobs Phone: 651-266-9054

- Basement - Water Heater - No gas shut off or gas piping incorrect (IFGC 402.1)
- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - gas venting incorrect (IFGC 503)
- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Piping - boiler fill water line requires backflow assembly or device (MPC 2100)
- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Water Heater - pipe backflow required on boiler to within 12 inches of floor.
- Basement - Soil and Waste Piping - improper pipe supports (MPC 1430 Subp. 4)
- Basement - Soil and Waste Piping - unplugged or open piping; back pitched piping (MPC 1000)
- Basement - Gas Piping - range gas shut off; connector or piping incorrect (IFGC 411 1.3.3) also, install gas piping to code and test.
- Basement - Laundry Tub - provide a vacuum breaker for the spout (MPC 2000 B)
- Basement - Laundry Tub - waste incorrect (MPC 2300)
- First Floor - Gas Piping - range gas shut off; connector or piping incorrect (IFGC 411 1.3.3)
- Comments: - Check for permits for first and second floor kitchen sink and full baths. Work done very recently. Need air test on waste and vent and new gas pipe.
- Obtain plumbing permits prior to commencement of work.

HEATING **Inspector: Kevin Chapdelaine** **Phone: 651-266-9042**

- Install approved lever handle manual building shutoff gas valve in an accessible location ahead of the first branch tee.
- Clean and Orsat test both boiler burners. Check all controls for proper operation. Provide documentation from a licensed contractor that the heating units are safe.
- Vent clothes dryer to code.
- Provide heat in every habitable room and bathrooms.
- Conduct witnessed pressure tests on hot water heating and gas piping systems.
- Repair or replace radiator valves as needed.
- Install heating system to code.
- Gas and hydronic mechanical permits are required for the above work and installation of new boilers.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **August 16, 2012** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Matt Dornfeld** between the hours of 8:00 and 9:30 a.m. at **651-266-1902**, or you may leave a voice mail message.

Sincerely,

Matt Dornfeld
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council