



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 11, 2011

Kathy Kirk
1889 Palace Ave
St. Paul, MN 55105

Re: Appeal for property at 1889 Palace Avenue
File ID: ALH 11-304

Dear Ms. Kirk:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of three double hung replacement egress bedroom windows which measured at 20 inches high by 23.3 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)
File

