



APPLICATION FOR APPEAL

RECEIVED

SEP 06 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday,	<u>9-20-11</u>
Time	<u>1:30</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

email 9-6-11

Address Being Appealed:

Number & Street: 1865 Ford Parkway City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 09/02/11

Name of Owner (if other than Appellant): Tom Collins

Address (if not Appellant's): 1865 Ford Parkway

Phone Numbers: Business _____ Residence 651-699-1731 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows
that will not comply w/ Egress Policy. Operable
Height will be short by 5" All other
criteria will be exceeded. please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 2, 2011

APPEAL PROPERTY ADDRESS: 1865 FORD PKWY

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 271487

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	9.4 sq.ft	Difference from Required Area	+4.4 sq.ft
Width of Opening Minimum 20 Inches	36"	Difference from Required Opening	+16 "
Height of Opening Minimum 24 Inches	18 7/8"	Difference from Required Opening	-5 1/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 2, 2011

APPEAL PROPERTY ADDRESS: 1865 FORD PKWY

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 271487

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	7.8 sq.ft.	Difference from Required Area	+2.8 sq.ft
Width of Opening Minimum 20 Inches	30"	Difference from Required Opening	+10"
Height of Opening Minimum 24 Inches	18 7/8"	Difference from Required Opening	-5 1/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps