

□ Other

MAR 1 1 2011
APPLICATION FORMAPEREAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to pr	ocess your appeal:	YOUR HEARING Date and Time:	
\$25 filing fee payable to the City of S			
(if cash: receipt number)		Tuesday, 4-5-11	
Copy of the City-issued orders or let	ter which		
are being appealed		Time	
Attachments you may wish to include	le	Location of Hearing:	
This appeal form completed		Room 330 City Hall/Courthouse	
Address Being Appeal			
Number & Street: //06 /3	REEN/ StCity: 5	4 PAUL State: MN Zip: 55 106	
Appellant/Applicant: MAKK U	WPERDAHC Em	ail <u>DEBBIEDMUD ROL</u>	Con.
Phone Numbers: Business	Residence 65/	163 468 (Cell	
Signature: Mark Lusler	dall	Date: 3-10-11	
Name of Owner (if other than Appellant):			5509
		< Rd ME Stacy M	110
Phone Numbers: Business	Residence	Cell	
What Is Being appeale	d and why?	Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O			
□ Summary/Vehicle Abatement			
□ Fire C of O Deficiency List			
Fire C of O: Only Egress Windows	RES # 1106	, 12 # 1	
□ Code Enforcement Correction Notice			
□ Vacant Building Registration			
□^Other	PAINTING .	of GARAGE # 2	
n Other	7	1	



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806 Telephone: 651-266-8989 Fax: 651-266-8951

March 1, 2011

Mark Underdahl 8560 Fawn Lake Rd Ne Stacy MN 55079-9499

FIRE CERTIFICATE OF OCCUPANCY APPROVAL WITH CORRECTIONS

RE:

1106 BREEN ST

Ref. # 110613

Dear Property Representative:

Your building was inspected on March 1, 2011 for the renewal of the Fire Certificate of Occupancy and was approved. When the required fee has been paid you will receive your certificate. There are however seasonal or non-life safety deficiencies noted below which must be corrected prior to re-inspection.

The following deficiencies must be corrected immediately. A reinspection will be made on April 4, 2011 at 1:00.

DEFICIENCY LIST

- 1. 2nd floor MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupanices handout for more information.-double hung removable window. Openable area 24 inches wide by 17 inches high, bottom section removed measurement of opening is 24 inches wide by 21 inches high.
- 2. Garage SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
- 3. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 4 UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

If you have any questions, email me at: pat.fish@ci.stpaul.mn.us or call me at 651-266-8942 between 7:30 a.m. - 9:00 a.m.

Sincerely,

Pat Fish Fire Inspector

Ref. # 110613