



APPLICATION FOR APPEAL

✓ Scanned

Saint Paul City Clerk

RECEIVED 310 City Hall, 15 W. Kellogg Blvd.
JUN 27 2011 Saint Paul, Minnesota 55102
Telephone: (651) 266-8560
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number Cash)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 7-5-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 697 5th St E City: St. Paul State: MN Zip: 55104

Appellant/Applicant: TriKin Holdings Email curt@trikinproperties.com

Phone Numbers: Business 651-964-3812 Residence _____ Cell 651-307-2357

Signature: [Handwritten Signature] Date: 6-27-11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 21, 2011

APPEAL PROPERTY ADDRESS: 697 5TH ST E

APPLICANT NAME: TRIKIN LLC

PHONE NUMBER: 651-307-2357

PERMIT NUMBER: 11 013818

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1 in upper unit

Total Glazed Area Minimum 5 Square Feet	9.25 sq ft.	Difference from Required Area	+ 3.5 sq ft.
Width of Opening Minimum 20 Inches	18 in.	Difference from Required Opening	- 2 in.
Height of Opening Minimum 24 Inches	30 in.	Difference from Required Opening	+ 6 in.
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	19 in.	Difference from Maximum Height	+ 23 in.

COMMENTS: 2nd floor east bedroom

Reviewed by: Virgil E. Thomas