



APPLICATION FOR APPEAL

RECEIVED

JUN 24 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-5-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

WALK-IN

Address Being Appealed:

Number & Street: 1375 Margaret St City: St. Paul State: MN Zip: _____

Appellant/Applicant: Emmanuel D'Huyvetter Email dhuyvetter1@gmail.com

Phone Numbers: Business 1-715-429-1000 Residence _____ Cell _____

Signature: [Signature] Date: 6/24/11

Name of Owner (if other than Appellant): SS Energy Enterprises, LLC

Address (if not Appellant's): N 366d Hart Rd Humbird WI, 54746

Phone Numbers: Business 1-715-429-1000 Residence _____ Cell _____

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 24, 2011

APPEAL PROPERTY ADDRESS: 1375 MARGARET ST
APPLICANT NAME: FREDIS ARISTIDES QUINTANILLA
PHONE NUMBER: 651-776-2227
PERMIT NUMBER: 06 120126
TYPE OF WINDOW: Slider
NUMBER OF WINDOWS: 2

Total Glazed Area Minimum 5 Square Feet	9.2	Difference from Required Area	+4.2
Width of Opening Minimum 20 Inches	17	Difference from Required Opening	-3
Height of Opening Minimum 24 Inches	39	Difference from Required Opening	+15
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: D. Nelson (rr)