



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHOND: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Bryan Horton
Renewal By Andersen Corporation
Obo John Larson & Katy Schulz
1920 County Rd C W
Roseville MN 55113-0000

VIA EMAIL: bryan.horton@andersencorp.com

Re: Appeal of Window Permit for property at 1872 Munster Avenue
File No. ALH 10-501

Dear Mr. Horton:

This is to confirm that on December 8, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 5 3/16-inch variance on the openable height of two double hung replacement egress bedroom windows which measured at 18 13/16 inches high by 30 inches wide and a 1 ¼-inch variance on the openable height of two double hung replacement egress bedroom windows which measured at 22 ¾ inches high by 30 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
File