

RECEIVED

OCT 25 2010

CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, NOV. 2

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2005 STANFORD AVE City: ST. PAUL State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersenacorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Mary Jo Katras

Address (if not Appellant's): 2005 STANFORD AVE ST. PAUL MN 55105

Phone Numbers: Business 651-699-1483 Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing the replacement of 9
bedroom windows that will not comply w/
St. Paul Policy. All 9 windows are short
by 1/8" in operable height, operable
width and overall glazed area is met or
exceeded. Please Approve.



**CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM**

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 20, 2010

APPEAL PROPERTY ADDRESS: 2005 STANFORD AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 912447
TYPE OF WINDOW: Double hung
NUMBER OF WINDOWS: 5

Total Glazed Area	10.3	Difference from Required Area	+5.3
Width of Opening	24	Difference from Required Opening	+4
Height of Opening	22 7/8	Difference from Required Opening	-1 1/8
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended.

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 20, 2010

APPEAL PROPERTY ADDRESS: 2005 STANFORD AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 912447
TYPE OF WINDOW Double hung
NUMBER OF WINDOWS 4

Total Glazed Area	8.7	Difference from Required Area	+3.7
Width of Opening	20	Difference from Required Opening	0
Height of Opening	22 7/8	Difference from Required Opening	-1 1/8
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 10-20-10 rr

Reviewed by: Rehn