



APPLICATION FOR APPEAL

RECEIVED

FEB 08 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 905091)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 2-21-12

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 4 Maywood Place City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Patricia Noren Email pnorenn@hotmail.com

Phone Numbers: Business _____ Residence 651-487-5194 Cell _____

Signature:  Date: 2/8/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

I would please address the committee to approve my installed windows. We just replaced the same style & size that was originally installed. See Attachments.

Thank you.





CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 8, 2012

APPEAL PROPERTY ADDRESS: 4 MAYWOOD PLACE

APPLICANT NAME: PATRICIA A NOREN

PHONE NUMBER: 651-487-5194

PERMIT NUMBER: 11 313151

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 (WINDOW 1 OF 2)

| | | | |
|---|-------------|---|-------------|
| Total Glazed Area Minimum 5 Square Feet | 11.5 sq ft. | Difference from Required Area | +6.5 sq ft. |
| Width of Opening Minimum 20 Inches | 36" | Difference from Required Opening | + 16" |
| Height of Opening Minimum 24 Inches | 17" | Difference from Required Opening | -7" |
| Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings | 35" | Difference from Maximum Height | +9" |

COMMENTS: 1 of 2 pages

Reviewed by: Virgil E. Thomas



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 8, 2012

APPEAL PROPERTY ADDRESS: 4 MAYWOOD PLACE

APPLICANT NAME: PATRÍCIA A NOREN

PHONE NUMBER: 651-487-5194

PERMIT NUMBER: 11 313151

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 (2 of 2 windows)

| | | | |
|---|-------------|---|-------------|
| Total Glazed Area Minimum 5 Square Feet | 14.7 sq ft. | Difference from Required Area | +9.7 sq ft. |
| Width of Opening Minimum 20 Inches | 37" | Difference from Required Opening | + 17" |
| Height of Opening Minimum 24 Inches | 21" | Difference from Required Opening | -3" |
| Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings | 35" | Difference from Maximum Height | +9" |

COMMENTS: 2 of 2 pages

Reviewed by: Virgil E. Thomas