



APPLICATION FOR APPEAL

RECEIVED
OCT 07 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Oct. 18, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2053 Iowa Ave E City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Daniel Schwinghammer

Address (if not Appellant's): 2053 Iowa Ave E

Phone Numbers: Business _____ Residence 651-987-6908 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows that will not comply w/ Egress Policy.

Operable height will be short by 5" width & glazed area criteria is met/exceeded. Specific specs attached.

Please Approve.



W S & D Permit Service
9533 – 367th Street; North Branch, MN 55056
Phone 651-674-1766 – Fax: 651-674-6190

To Whom It May Concern:

I am an authorized agent by Renewal by Andersen to pull, pay for, and obtain their building permits. I have enclosed a self addressed stamped envelope for you convenience to mail the permit back to me. If there is a problem with this please feel free to give me a call at 651-674-1766.

Thank you for you assistance,

Kara Benson
WS&D Permit Service
651-674-1766 – Phone
651-674-6190 - Fax



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 3, 2011

APPEAL PROPERTY ADDRESS: 2053 IOWA AVE E
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 283929
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 2

| | | | |
|---|-----|---|------|
| Total Glazed Area Minimum 5 Square Feet | 9.5 | Difference from Required Area | +4.5 |
| Width of Opening Minimum 20 Inches | 36 | Difference from Required Opening | +16 |
| Height of Opening Minimum 24 Inches | 19 | Difference from Required Opening | -5 |
| Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings | <48 | Difference from Maximum Height | ok |

COMMENTS:

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 3, 2011

APPEAL PROPERTY ADDRESS: 2053 IOWA AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 283929

TYPE OF WINDOW Double Hung


NUMBER OF WINDOWS 1

| | | | |
|--|-----|---|------|
| Total Glazed Area <i>Minimum 5 Square Feet</i> | 7.3 | Difference from Required Area | +2.3 |
| Width of Opening <i>Minimum 20 Inches</i> | 28 | Difference from Required Opening | +8 |
| Height of Opening <i>Minimum 24 Inches</i> | 19 | Difference from Required Opening | -5 |
| Height of Opening to Finished Floor <i>Maximum 48 Inches for Existing Openings</i> | <48 | Difference from Maximum Height | ok |

COMMENTS:

Reviewed by: Rehn

United States Environmental Protection Agency



This is to certify that

Renewal by Andersen Corporation

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint renovation, repair, and painting activities pursuant to 40 CFR Part 745.89

For the Jurisdiction of:

All EPA Administered States, Tribes, and Territories

This certification is valid from the date of issuance and expires April 29, 2015

NAI-27283-1

Certification #

April 16, 2010

Issued On

Michelle Price, Chief

Lead, Heavy Metals, and Inorganics Branch