



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 0443 P. 2

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-23-12

APPEAL PROPERTY ADDRESS: 1298 SEMINARY

APPLICANT NAME: PUBLIC HEALTH (DANE SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 9.0 sqft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 25.2" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 19.9" DIFFERENCE FROM REQUIRED OPENING: 4.1"

HEIGHT OF OPENING
TO FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

St Paul-Ramsey Co. Public Health

Apr. 24. 2012 1:15PM

RECOMMENDATION (IF APPLICABLE):

RECEIVED
APR 24 2012
CITY CLERK

FROM: _____

Select a Model		Min. W: 11	Max. W: 52	
(Model 0201) Excalibur Double Hung		Min. H: 20	Max. H: 94	Max. U/I: 132
Top Sash Width	26.3750	Exact Size		
Top Sash Height	25.1250	Width: 29.625	29.625	
Bottom Sash Width	27.3750	Height: 53.325	53.325	
Bottom Sash Height	25.0750	Extrusion: Select Extrusion << Far Arch-Top Models Only		
Top Glass Width	24.6875	Opening: Exact Size		
Top Glass Height	23.4375	Type: Standard		
Bottom Glass Width	25.6875	Screen: Full		
Bottom Glass Height	24.3750	Glass: Double Strength (3 mm)		
Screen Width	25.9375	<input type="checkbox"/> AC Sash Calculator		
Screen Height	30.4375			
Top Sash Weight (Plus 5 lb)	21 lb			
Top Balance Size (C.F.)	66BU			
Top Balance Size (Spiral)	21-7B			
Bottom Sash Weight	17 lb			
Bottom Balance Size (C.F.)	9NAT			
Bottom Balance Size (Spiral)	25-6R			
Egress Opening Width	25.2190			
Egress Opening Height	19.9375			
Egress Opening Area (sq.ft.)	3.4820			

1298 SENINAM