



APPLICATION FOR APPEAL

RECEIVED

MAR 04 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 3/22/11

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

WALK-IN

Address Being Appealed:

Number & Street: 1019 Geranium AVE City: ST PAUL State: MN Zip: 55106

Appellant/Applicant: Brian L Cunningham Email _____

Phone Numbers: Business 763-742-2708 Residence SAME Cell SAME

Signature: Brian L Cunningham Date: 3-4-11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business 763 742 2708 Residence SAME Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration

☒ Other

☐ Other

☐ Other

Egress Window / main floor / 2nd BR

Address on check: 1166 Beech St.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 28, 2011

APPEAL PROPERTY ADDRESS: 1019 GERANIUM AVE E

APPLICANT NAME: BRIAN CUNNINGHAM

PHONE NUMBER: 651-266-9023

PERMIT NUMBER: 09 268927

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	10.6 sq. ft.	Difference from Required Area	+ 4.6
Width of Opening Minimum 20 Inches	24 in.	Difference from Required Opening	+4 in.
Height of Opening Minimum 24 Inches	19.75	Difference from Required Opening	- 4.25 in.
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	31 in.	Difference from Maximum Height	+ 16 in.

COMMENTS:

Reviewed by: Virgil E. Thomas