



# APPLICATION FOR APPEAL

Saint Paul City Clerk  
15 W. Kellogg Blvd., 310 City Hall  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8688

RECEIVED  
SEP 23 2010  
CITY CLERK

1. Address of Property being Appealed: <u>290 Burlington Rd</u>	2. Number of Dwelling Units: <u>Single Family</u>	3. Date of Letter Appealed: <u>09-15-10</u>
--	--	--

4. Name of Owner: Doris Schrenkler  
 Address: 290 Burlington Rd City: St. Paul State: MN Zip: 55119  
 Phone Numbers: Business \_\_\_\_\_ Residence 651-735-1892 Cellular \_\_\_\_\_  
 Signature: \_\_\_\_\_

5. Appellant / Applicant (if other than owner): Renewal by Andersen  
 Address: 1920 W GY Rd C City: Roseville State: MN Zip: 55113  
 Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cellular \_\_\_\_\_  
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):  
We are appealing 5 replacement windows that will not comply with Egress Requirements. Windows being replaced are all lower level bedrooms where the home is sided w/ stucco and brick. Unable to make alterations to window height and homeowner does not want to change style. Please Approve.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>9/23/10</u>	Fee Received: <u>25 pd.</u>	Receipt Number:	Date of Hearing: <u>Oct 5 11:30</u>
----------------------------------	--------------------------------	-----------------	--

Room 330 City Hall



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

RECEIVED  
SEP 23 2010  
CITY CLERK

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: September 16, 2010

APPEAL PROPERTY ADDRESS: 290 BURLINGTON ROAD  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 10 899199  
TYPE OF WINDOW Double Hung  
NUMBER OF WINDOWS 5

Total Glazed Area	8.7 sq. ft.	Difference from Required Area	+ 3.7 sq. ft.
Width of Opening	24"	Difference from Required Opening	+ 4 "
Height of Opening	18 7/8 "	Difference from Required Opening	- 5 1/8 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.