

We need the following to process your appeal:

(if cash: receipt number 194626

APPLICATION FOR APPEAL

Saint Paul City Council - Legislative Hearings

Tuesday, Jahuar

RECEIVED

DEC 2 2015

CITY CLERK

\$25 filing fee (non-refundable) (payable to the City of Saint Paul) HEARING DATE & TIME

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8585

Revised 8/11/2014

(provided by Legislative Hearing Office)

Copy of the City-issued orders/letter being appealed Attachments you may wish to include This appeal form completed	Tuesday, Jahran 5th 2014 Time_1130 AM
□ Walk-In OR □ Mail-In	Location of Hearing: Room 330 City Hall/Courthouse
for abatement orders only: Email OR Fax	Room 550 City Huit/Courthouse
Address Being Appealed:	
Number & Street: 740 Stewart Auc City: 10	
Appellant/Applicant:	nail MN Leafless gutters @ 6m
Phone Numbers: Business 6/2-221-0362 Residence	Cell
Signature:	
Name of Owner (if other than Appellant):	
Mailing Address if Not Appellant's:	
Phone Numbers: Business Residence	Cell
	Attachments Are Acceptable
Summary/Vehicle Abatement	
□ Fire C of O Deficiency List/Correction	*
Use Vacant Building Registration	
Other (Fence Variance, Code Compliance, etc.)	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul. Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

December 15, 2015

Tim Hanson 740 Stewart Ave Unit 2 Saint Paul MN 55102-4119

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE:

740 STEWART AVE

Ref. # 16272

Dear Property Representative:

Your building was inspected on December 10, 2015, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on January 11, 2016 at 9:30 AM or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

- 1. Basement Water heater UMC 1346.703 Provide 30 inches clearance around all mechanical equipment.
- 2. Exterior Rear SPLC 65.141 (g) There shall be no exterior storage of equipment, supplies or commercial vehicles associated with the home occupation, nor parking of more than one (1) business car, pickup truck or small van, nor any additional vehicles except those for permitted employees identified under paragraph (d).
- -Remove all business equipment including wood pallets, pump jacks, siding materials, ladders, planks and stored rain gutters.
- 3. Exterior Rear SPLC 34.08 (6), 34.31 (4) Remove the accumulation of exterior storage that creates a nuisance or harbors rodents. -Remove all pallets, construction material and work equipment from the property.

- 4. Rear SPLC 34.08 (7) All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-8989.
- 5. Unit 3 MSFC 703 Provide, repair or replace the fire rated door and assembly. -Repair and maintain the door closer.
- 6. Unit 3 MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.
- 7. Unit 4 Hallway MSFC 1028.3 Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway. -Move shoe rack from blocking door from opening fully.
- 8. Unit 4 Kitchen MSFC 605.4 Discontinue use of all multi-plug adapters.
- 9. Unit 4 MSFC 703 Provide, repair or replace the fire rated door and assembly. -Repair and maintain the door closer.
- 10. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 11. MSFC 304.3.3 Relocate dumpster at least 5 feet away from combustible walls, openings, or combustible eaves and overhangs.
- 12. MSFC 901.6 Provide required annual maintenance of the fire extinguishers by a qualified person and tag the fire extinguishers with the date of service.
- 13. SPLC 34.19 Provide access to the inspector to all areas of the building.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Justin.Elvestad@ci.stpaul.mn.us or call me at 651-266-8982 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Justin Elvestad Fire Inspector Ref. # 16272