



Fire Inspection Report

City of Saint Paul

Department of Safety and Inspections
375 Jackson Street – Suite 220
Saint Paul MN 55101-1806

Owner Name Cordell & Anne Edmunds
Owner Address 4893 Hillvale Ave N
City State Zip Oakdale, MN 55128
Owner Phone Housing Hub 651-488-2437

License _____
Complaint _____
C of O _____
Date _____

Building Address: 950 Arkwright St

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 310 City Hall 651-266-8585 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
SPLC	Remove Bed From Rear Balcony - Unapproved
§	Sleeping Area - Temp Not Maintained 68° -
MSFC	Non Insulated - Do Not Use For Sleeping

Owner or Representative Signature *Amelia Sander*

Occupancy Type R-3 Inspector Signature *[Signature]*
CFO Key _____ Reinspection Date 10/23/2023 3:00pm

** For further information on this report, contact the Fire Inspection Division at 651-266-8989 **