



APPLICATION FOR APPEAL

RECEIVED

OCT 31 2011

CITY CLERK

RECEIVED

OCT 31 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11-8-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2248 Matherhorn Ln City: St. Paul State: MN Zip: 551

Appellant/Applicant: A Pane In The Glass Const. Email Allen@mnwindows.com

Phone Numbers: Business 651-329-4815 Residence _____ Cell 651-373-0377

Signature: [Signature] Date: 10-31-11

Name of Owner (if other than Appellant): Angela Polacek

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell 651-216-8452

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

different opening measurements than required



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 31, 2011

APPEAL PROPERTY ADDRESS: 2248 MATTERHORN LANE

APPLICANT NAME: A PANE IN THE GLASS CONSTRUCTION LLC

PHONE NUMBER: 651-329-4815

PERMIT NUMBER: 11 292647

TYPE OF WINDOW ~~Double Hung~~ 2-lite slider

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	5.13 sq. ft.	Difference from Required Area	+ .13
Width of Opening Minimum 20 Inches	17.125"	Difference from Required Opening	-2.875
Height of Opening Minimum 24 Inches	38.25"	Difference from Required Opening	+14.25
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 10-31-11