



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

JAN 04 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 1-11-2011

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1828 Montreal Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Amy & Jeff Akh

Address (if not Appellant's): 1828 Montreal Ave

Phone Numbers: Business _____ Residence 651-698-5740 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

WE are appealing 7 replacement windows that will not comply w/ Egress Policy. 3 windows will be 5 1/8" short in operable height the other 4 will only be 1 1/8" short in operable height. Operable width and overall glazed area met and/or exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 30, 2010

APPEAL PROPERTY ADDRESS: 1828 MONTREAL AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 939828
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 3

Total Glazed Area	11.5 sq. ft.	Difference from Required Area	+ 6.5 sq. ft.
Width of Opening	32"	Difference from Required Opening	+ 12"
Height of Opening	18 7/8"	Difference from Required Opening	- 5 1/8"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 30, 2010

APPEAL PROPERTY ADDRESS: 1828 MONTREAL AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 939828
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 4

Total Glazed Area	10.3 sq. ft.	Difference from Required Area	+ 5.3 sq. ft.
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	22 7/8"	Difference from Required Opening	- 1 1/8"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.