



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 19, 2011

Window World
Esther Dahl
esterhd@windowworldmn.com
2211 11th Ave E - #130
North St Paul MN 55109

Re: Appeal for property at 1850 Princeton Avenue (Nikki Johnson)
File ID: ALH 11-73

Dear Ms. Dahl:

This is to confirm that on January 12, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of three double hung replacement egress bedroom windows which measured at 20 inches high by 24 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/
Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File

