



APPLICATION FOR APPEAL

RECEIVED

DEC 11 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, Dec. 18, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1966 Benson Avenue City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Matt Connelly Email matt@amidographics.com

Phone Numbers: Business 651-690-2401 Residence _____ Cell 651-329-7288

Signature: Matthew J. Connelly Date: 12-11-2012

Name of Owner (if other than Appellant): Paul S. Amidon

Address (if not Appellant's): 1966 Benson Avenue St. Paul MN 55116

Phone Numbers: Business 651-690-2401 Residence 651-698-3198 Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Roll storage from 12 feet to 16 feet.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

December 6, 2012

PAUL AMIDON
AMIDON GRAPHICS
1966 BENSON AVE
SAINT PAUL MN 55116

FIRE INSPECTION CORRECTION NOTICE

RE: 1966 BENSON AVE
Ref. #14776

Dear Property Representative:

Your building was inspected on November 29, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made on January 3, 2013 at 1:00 pm.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

- Exterior -Entry Doors** - MSFC 2703.5 - Provide NFPA 704 hazard identification HM-1.
Blue = 2 Red = 4 Yellow = 0 White = leave blank Size = 6 inch min.
See handout on DSI website at: www.stpaul.gov/dsi > Fire Certificate of Occupancy > Hazard Identification Placard Information (for HM-1).-
Provide updated hazard placards posted at exterior entry doors to the building.
- Near Stevens/ Prep** - M100s Mezzanine - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway. - *Maintain clear aisle through the mezzanine area.*

Greg & Matt

Matt

3. **Near Stevens/ Prep** - MSFC 1010.5 - Provide and maintain an approved emergency lighting system. - *Repair non-working emergency light.*
4. **Paper Storage and Box Storage Warehouse Areas** - MSFC 2302.1 - Reduce and maintain storage height to 12 feet or less or provide approved high-piled storage protection to code under permit.

Gray
Mike & Hue

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson
Fire Inspection

Reference Number 14776