



|
: Mike Rick <mrick@totalmech.com>
: "gapylkas@netzero.net" <gapylkas@netzero.net>
: 1756 East Iowa St Paul MN 55106
: Fri, Apr 10, 2015 08:25 AM

Grant

We inspected and repaired the vent piping at the above address.

All joints were repaired, and taped with UL listed 181 aluminum tape.

This was done by Dan Hoffman St Paul Master Vent card number 20110000015.



Mike Rick

Total Mechanical Services, Inc.

420 Broadway Ave

St. Paul Park, MN 55071

Ph: 651-768-9367 Ext 109

Fax: 651-768-9258

Cell: 651-775-5943