



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

March 21, 2012

XENG XIONG
762 JESSIE ST
ST PAUL MN 55130-4121

NOTICE OF CONDEMNATION UNFIT FOR HUMAN HABITATION ORDER TO VACATE

RE: 678 JESSAMINE AVE E
Ref. # 108284

Dear Property Representative:

Your building was inspected on March 14, 2012.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

A reinspection will be made on or after April 13, 2012.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.-Lack of water service, have resored.

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
3. SPLC 34.11(4), 34.34(1) SPC 4715.0200A - Provide an adequate water supply to all water closets, sinks, showers and tubs.-Have meter work done and water turned on.
4. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: mike.cassidy@ci.stpaul.mn.us or call me at 651-266-8984 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy
Fire Inspector
Ref. # 108284

cc: Housing Resource Center
Force Unit