

✓ Scanned

Hearing 6/19/12
11:30



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

P. 2
No. 1083

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 6-6-12

APPEAL PROPERTY ADDRESS: 963 JUNO AVE

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.4 sqft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 23.2" DIFFERENCE FROM REQUIRED OPENING: .8"

HEIGHT OF OPENING: 20" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING ABOVE FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

FROM: _____

Jun. 6. 2012 3:37PM