

Scanned



APPLICATION FOR APPEAL

RECEIVED
JAN 10 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 1-18-2011

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1850 Princeton City: _____ State: _____ Zip: _____

Appellant/Applicant: Window World-Esther Dahl Email estherd@windowworldmn.com

Phone Numbers: Business 651-770-9315 Residence _____ Cell _____

Signature: Esther Dahl Date: 1/6/11

Name of Owner (if other than Appellant): Nikolaj Johnson

Address (if not Appellant's): 1850 Princeton Ave

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other Asking for Variance on windows, we exceed 3 out of 4 requirements
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 22, 2010

APPEAL PROPERTY ADDRESS: 1850 PRINCETON AVE

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-266-9025

PERMIT NUMBER: 10 898797

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3 in a row, same bedroom.

Total Glazed Area	8 Sq. Ft.	Difference from Required Area	2.3 Sq Ft.
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	20"	Difference from Required Opening	- 4"
Height of Opening to Finished Floor	32"	Difference from Maximum Height	12"

COMMENTS: Windows do not meet the St. Paul egress code for bedrooms. Windows in all other bedrooms are the same size as the new windows.

Reviewed by: Michael A. Palm

Select a Model

(Model 0201)		0201 ▼
Excalibur Double Hung		
Top Sash Width		26.3750
Top Sash Height		27.0625
Bottom Sash Width		27.3750
Bottom Sash Height		28.0625
Top Glass Width		24.6875
Top Glass Height		25.3750
Bottom Glass Width		25.6875
Bottom Glass Height		26.3750
Screen Width		25.9375
Screen Height		28.3125
Top Sash Weight (Plus 5 lb)		22 lb
Top Balance Size (C.F)		56BU
Top Balance Size (Spiral)		23-9R
Bottom Sash Weight		18 lb
Bottom Balance Size (C.F)		9NAT
Bottom Balance Size (Spiral)		27-7R
Egress Opening Width		25.2190
Egress Opening Height		21.8750
Egress Opening Area (sq.ft.)		3.8310

Min. W: 11		Max W: 52	
Min. H: 20		Max H: 84	
Max UI: 132			
Exact Size			
Width:	29 5/8	29.625	
Height:	57 1/4	57.25	
Extrusion:	Select Extrusion ▼	<< For Arch-Top Models Only	
Opening:	Exact Size ▼		
Type:	Standard ▼		
Screen:	Half ▼		
Glass:	Double Strength (3 mm) ▼		

 AC Sash Calculator