



RECEIVED
FEB 06 2012
CITY CLERK

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 2-21-12

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2051 Nortonia St City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Home Depot at home Services Email mknoll@THDat homeservices.com

Phone Numbers: Business 763-852-1044 Residence _____ Cell 763-238-0949

Signature: [Handwritten Signature] Date: 1-23-2012

Name of Owner (if other than Appellant): Justin Vick

Address (if not Appellant's): 2051 Nortonia St. St. Paul

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice Egress window compliance
- Vacant Building Registration _____
- Other _____

Attention Simon



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 2, 2011

APPEAL PROPERTY ADDRESS: 2051 NORTONIA AVE

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 770-779-1300

PERMIT NUMBER: 10 913700

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS One

Total Glazed Area Minimum 5 Square Feet	7.1 sq.ft.	Difference from Required Area	+1.4 sq. ft.
Width of Opening Minimum 20 Inches	31"	Difference from Required Opening	+11"
Height of Opening Minimum 24 Inches	12"	Difference from Required Opening	-12"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	

COMMENTS:

Please Resolve this order!
David N.

Reviewed by: David Nelson

266 9027