

RECEIVED

SEP 02 2010

CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <i>2086 Princeton Ave</i>	2. Number of Dwelling Units: <i>Single Family</i>	3. Date of Letter Appealed: <i>08/31/10</i>
---	--	--

4. Name of Owner: *Elyse Duffly*
 Address: *Site Address* City: *St. Paul* State: *MN* Zip: *55105*
 Phone Numbers: Business _____ Residence *651-690-9050* Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): *Renewal by Andersen*
 Address: *1920 W CH Rd C* City: *Roseville* State: *MN* Zip: *55113*
 Phone Numbers: Business *651-264-4088* Residence _____ Cellular _____
 Signature: *Bryan Horton*

6 State specifically what is being appealed and why (Use an attachment if necessary):

*We are appealing 2 replacement windows that will not comply with the height Requirement stated in the Egress Policy. Windows, at their current dimensions will comply w/ policy requirements in width and overall glazed area.
Please Approve*

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <i>Sept. 14</i>	Fee Received: <i>\$25</i>	Receipt Number:	Date of Hearing:
-----------------------------------	------------------------------	-----------------	------------------

Revised 4/25/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 31, 2010

APPEAL PROPERTY ADDRESS: 2086 PRINCETON AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 798991

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area	10.3 sq. ft.	Difference from Required Area	+ 5.3 sq. ft.
Width of Opening	24 "	Difference from Required Opening	+ 4 "
Height of Opening	22 "	Difference from Required Opening	- 2 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.