



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

October 13, 2011

CECIL DELICATESSEN
651 CLEVELAND AVE S
ST. PAUL MN 55116

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
651 CLEVELAND AVE S
Ref. # 15815

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on October 12, 2010. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. **A re-inspection will be made on or after November 30, 2011.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

1. OCCUPANT LOAD - MSFC 1027.1.3 - Reduce the number of tables and chairs to 65.- Reduce tables and chairs and remove old occupant load sign.
2. OCCUPANT LOAD - MSFC 1003.2.2.5 - Post the occupant load on an approved sign in a conspicuous location near the main exit of the room.-OCCUPANT LOAD: 65

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at Kris.skow-fiske@ci.stpaul.mn.us or call me at 651-266-8949 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,
Kris Skow-Fiske
Fire Inspector

An Equal Opportunity Employer