



# APPLICATION FOR APPEAL RECEIVED

Saint Paul City Clerk  
15 W. Kellogg Blvd., 310 City Hall  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8688

NOV 09 2010  
CITY CLERK

1. Address of Property being Appealed: <u>528 GALTIER ST.</u>	2. Number of Dwelling Units: <u>1</u>	3. Date of Letter Appealed:
--	--	-----------------------------

4. Name of Owner: WENSHYAN WANG  
 Address: 339 Moreland Cir. City: W. Saint Paul State: MN Zip: 55118  
 Phone Numbers: Business 651-2052425 Residence 6512528076 Cellular 6512528076  
 Signature: Wenshan Wang

5. Appellant / Applicant (if other than owner): \_\_\_\_\_  
 Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_  
 Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cellular \_\_\_\_\_  
 Signature: \_\_\_\_\_

6 State specifically what is being appealed and why (Use an attachment if necessary):  
Hope to be allowed for the variance - the window has plenty of height and the shortage of 1.5 inches shouldn't have that much of impact. Thanks.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

### For Office Use Only

Date Received: <u>11/9/10</u>	Fee Received: <u>25 cash</u>	Receipt Number:	Date of Hearing: <u>11/16/10 2:30</u>
----------------------------------	---------------------------------	-----------------	--



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: November 9, 2010

APPEAL PROPERTY ADDRESS: 528 GALTIER ST

APPLICANT NAME: WENSHYAN WANG

PHONE NUMBER: 651-266-9046

PERMIT NUMBER: 10 605977

TYPE OF WINDOW DH

NUMBER OF WINDOWS 1

<b>Total Glazed Area</b>	10	<b>Difference from Required Area</b>	+5
<b>Width of Opening</b>	18.5	<b>Difference from Required Opening</b>	_1.5
<b>Height of Opening</b>	29	<b>Difference from Required Opening</b>	+5
<b>Height of Opening to Finished Floor</b>	-----	<b>Difference from Maximum Height</b>	-----

COMMENTS:

Reviewed by: