



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

331.0

February 24, 2017

12-015518

Ahmad Kian
3800 Xerxes Ave S
Minneapolis MN 55410-1133

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

947 BARCLAY ST

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Fairchilds Re Of L8 15 B1 Lot 2 Blk 2

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On February 15, 2017 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one-story, wood frame, single-family dwelling with a detached, one-stall garage.

The following is excerpted from the April 11, 2013 Code Compliance Report:

BUILDING

- Dry out basement and eliminate source of moisture.
- Remove mold, mildew and moldy or water damaged materials.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Provide functional hardware at all doors and windows
- Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.
- Install floor covering in bathroom and kitchen that is impervious to water.
- Repair walls, ceiling and floors throughout, as necessary.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
- Provide fire block construction as necessary and seal chases in basement ceiling.
- Where wall and ceiling covering is removed install full thickness or code-specified insulation.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Provide proper drainage around house to direct water away from foundation of garage.
- Install downspouts and a complete gutter system.
- Install rain leaders to direct drainage away from foundation.
- Install flashing in an approved manner at the intersection of the roof with walls, chimneys, and other conjoined surfaces.
- Install address numbers visible from street and on the alley side of garage.
- Provide durable, dustless parking surface as specified in the zoning code.
- Remove trees which are against foundation of home and garage.
- Grade must drain away from foundation of dwelling. Maintain 6 inch clearance between wood and soil.
- Remove all wall and ceiling covering from basement.

- Double up floor joist under kitchen area.
- Install safety glass in window at top of basement stairs.
- Repair broken treads on basement stairs.
- Basement bedroom not legal for bedroom.
- Replace flashing on chimney and elec. mast.
- Totally rebuild garage to code or remove.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits
- Verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Install S type fuse adapters and proper size S fuses listed circuit breakers
- Verify that fuse amperage matches wire size
- Close openings in service panel/junction boxes with knockout seals, breaker blanks, and/or junction box covers
- Properly strap cables and conduits in basement/ conduit and service conduit on the exterior of the house.
- Install/replace GFCI receptacle in first bathroom adjacent to the sink - Verify the location of the GFCI receptacle for the usage of a cord plugged in. Relocate if needed.
- Remove all cord wiring
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Remove any 3-wire ungrounded outlets and replace with 2-wire or ground 3-wire to code
- Install hard-wired, battery backup smoke detector and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement/garage/stairway wall to basement
- Replace all painted-over receptacles.
- Based on repair list purchase permit for 8 circuits
- Verify wiring to all electrical heaters. Wire to 2011 NEC
- Add 2 receptacles - 1 on north living room wall and 1 in upper bedroom northwest area
- Verify any wiring to shed. Remove or rewire to 2011NEC. No entry at time of inspection.
- Need bonding bushing at panel
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.

- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - No gas shut off or gas piping incorrect (MFGC 402.1)
- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - Vent must be in chimney liner (MFGC 501.12)
- Basement - Water Heater - Water piping incorrect (MPC 1730 Subp. 1)
- Basement - Water Heater - gas venting incorrect (MFGC 503)
- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Meter - meter is removed or not in service (MPC 4715.1700)
- Basement - Water Piping - improper fittings or usage (MPC 0420)
- Basement - Water Piping - pipe sizing incorrect (MPC 4715.1730)
- Basement - Water Piping - provide water piping to all fixtures and appliances (MPC 1700)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)
- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Gas Piping - add appropriate metal hangers (MFGC 407.2)
- Basement - Gas Piping - replace improper piping or fittings (MFGC 411)
- Basement - Soil and Waste Piping - improper connections, transitions, fittings or pipe usage (MPC 2420)
- Basement - Soil and Waste Piping - improper pipe supports (MPC 1430 Subp. 4)
- Basement - Soil and Waste Piping - no soil stack base clean out
- Basement - Soil and Waste Piping - replace corroded cast iron or steel waste piping (MPC 0200)
- Basement - Soil and Waste Piping - replace the floor drain cover or clean out plug (MPC 1300)
- Basement - Soil and Waste Piping - unplugged or open piping; back pitched piping (MPC 1000)
- All Fixtures on First Floor - Plumbing - General - Plumbing was installed without permits and no inspections. Obtain proper permits and provide for proper tests and inspections (0320 Subp. 3)
- First Floor - Re-pipe all first floor waste, vent and water piping to all first floor fixtures according to code.
- First Floor - Gas Piping - range gas shut off; connector or piping incorrect (MFGC 411)
- First Floor - Lavatory - incorrectly vented (MPC 2500)
- First Floor - Lavatory - waste incorrect (MPC 2300)
- First Floor - Sink - unvented (MPC 0200. E)
- First Floor - Sink - waste incorrect (MPC 2300)
- First Floor - Sink - water piping incorrect (MPC 0200 P.)
- First Floor - Toilet Facilities - unvented (MPC 0200. E)
- First Floor - Toilet Facilities - waste incorrect (MPC 2300)
- First Floor - Tub and Shower - Provide access (MPC 0900)
- First Floor - Tub and Shower - faucet is missing, broken or parts missing (MPC 0200. P.)

- First Floor - Tub and Shower - incorrectly vented (MPC 2500)
- First Floor - Tub and Shower - replace waste and overflow (MPC 1240)
- First Floor - Tub and Shower - waste incorrect (MPC 2300)
- Exterior - Install one 3 inch full size stack undiminished in size out the roof.
- Exterior - Piping Vents - Incorrect sizing (MPC 2530 Subp. 2)
- Exterior - Piping Vents - vent pipes required (MPC 0200.E.)
- All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4715 & Chapter 326, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and the Saint Paul Regional Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul under an approved permit.

HEATING

- Install approved level handle manual gas shutoff valve on space heater and remove unapproved valve.
- Clean and Orsat test space heater burner. Check all controls for proper operation. Check heat exchanger for leaks; provide documentation from a licensed contractor that the heating unit is safe.
- Install approved metal chimney liner.
- Provide adequate clearance from flue vent pipe on space heater to combustible materials or provide approved shielding according to code.
- Vent clothes dryer to code
- Provide adequate combustion air and support duct to code
- Provide support for gas lines to code
- Plug, cap and/or remove all disconnected gas lines
- Provide a window in the bathrooms with an aggregate glazing area of not less than 3 square feet, one-half of which must be openable or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- Provide heat in every habitable room and bathrooms
- Mechanical gas permit is required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **March 26, 2017** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Rich Singerhouse** between the hours of 8:00 and 9:30 a.m. at **651-266-1945**, or you may leave a voice mail message.

Sincerely,

Rich Singerhouse
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council