



APPLICATION FOR APPEAL

RECEIVED
AUG 17 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
 - Copy of the City-issued orders or letter which are being appealed
 - Attachments you may wish to include
 - This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:	
Tuesday,	<u>9-6-11</u>
Time	<u>1:30</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

Address Being Appealed:

Number & Street: 1074 Jessie City: St Paul State: Mn Zip: _____

Appellant/Applicant: Kendall Burton Email _____

Phone Numbers: Business _____ Residence _____ Cell 651-246-9908

Signature: Kendall Burton Date: 8/17/11

Name of Owner (if other than Appellant): Ann Burton

Address (if not Appellant's): E 1340 1205th Ave Downing WI 54734

Phone Numbers: Business 715643 2018 Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

H
22 1/2 x 26 7/8 W Window opening



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 15, 2011

Ann Burton
E1340 1205th Ave
Downing WI 54734-9499

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
1074 JESSIE ST

Ref. # 114119

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on June 9, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

A reinspection will be made on or after July 22, 2011.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. INTERIOR - UNIT 2 - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Upon inspection, double-hung window in east bedroom of Unit 2 measured 21 inches openable height x 27 inches openable width.
2. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at kelly.booker@ci.stpaul.mn.us or call me at 651-266-8985 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kelly Booker
Fire Inspector
Ref. # 114119



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

**SMOKE AND CARBON MONOXIDE DETECTOR
INSPECTION AFFIDAVIT**

** This affidavit must be completed and returned to the fire inspector upon inspection of the property. A certificate of occupancy cannot be issued/renewed without this completed affidavit. If all the units were not inspected by one person, signatures of all persons inspecting are required. More than one sheet may be used. **

1074 Jessie _____ 2 _____
Address # of Units C of O #

I affirm that I have given the occupant of each dwelling unit or guest room in the building at the above address a written explanation of the following:

1. The location and operation of each smoke detector and carbon monoxide detector.
2. Instructions describing the action to be taken when an alarm sounds.
3. The procedures for testing the detectors.
4. Who to contact when a low-battery tone sounds or power light fails.
5. The penalties for disabling smoke detection or carbon monoxide detection.

Signature: Kendall Burtas Date: 8/17/11

I affirm that I personally inspected the smoke detectors and carbon monoxide detectors in the dwelling units and guest rooms in the building at the above address as follows and that all detectors were in place and good working order:

Apt. #	Apt. #	Apt. #	Apt. #	Apt. #	Apt. #
____	____	____	____	____	____
____	____	____	____	____	____
____	____	____	____	____	____
____	____	____	____	____	____
____	____	____	____	____	____
____	____	____	____	____	____
____	____	____	____	____	____

Signature: Kendall Burtas Date: 8/17/11

Minnesota State Statutes 299F.362 requires smoke detectors and Minnesota State Statute 299F.50 requires carbon monoxide detectors and Saint Paul Ordinance 39.02 (c) requires that an affidavit stating that "all detectors are inspected and serviced when needed and are operational be filed before a Certificate of Occupancy can be issued or renewed."

Revised 12/09