


Saint Paul - Ramsey County Department of Public Health  
Environmental Health Section  
2785 White Bear Avenue North Suite 350  
Maplewood, MN 55109-1320  
FAX: (651) 266-1177



Date: 6-7-11

RECEIVED  
MAY 20 2011  
CITY CLERK

To FAX#: 6-8574

FACSIMILE TRANSMISSION  
Cover Sheet and Transmittal Form

To:	<u>Mai Yang Paralegal</u>
Location:	<u>Legislative Hearing Office</u> <u>City of St. Paul</u>
Sender:	<u>Daniel Schmidt / Tim Yannarelli</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u>

This transmission consists of \_\_\_\_\_ pages (including cover sheet).  
If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Request for Egress Window Non-Compliance Determination  
Attachments: Egress Window Non-Compliance Determination Form

**CONFIDENTIALITY NOTICE**

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 5-20-11

APPEAL PROPERTY ADDRESS: 1147 MATILDA

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHAUB) PHONE NUMBER: 246-1143

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DR

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 9.8 sqft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 25" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: 2"


HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

St Paul Ramsey Co. Public Health  
2:07PM  
2011  
May 20, 2011

FROM: \_\_\_\_\_

Exhibit A



No. 7610 P. 2

Select a Model		Min. W: 11	Max. W: 52	Max. U: 132
(Model 0201)		Min. H: 20	Min. H: 34	
Excalibur Double Hung		Width: 28.5	Height: 57.625	Excalibur
Top Sash Width	28.2500			
Top Sash Height	27.2500			
Bottom Sash Width	27.2500			
Bottom Sash Height	28.2500			
Top Glass Width	28.2500			
Top Glass Height	25.5025			
Bottom Glass Width	25.5025			
Bottom Glass Height	25.5025			
Screen Width	25.4125			
Screen Height	54.7500			
Top Sash Weight (Plus 5 lb)	22 lb			
Top Balance Size (C-F)	RB1U			
Top Balance Size (Spring)	23.9R			
Bottom Sash Weight	19 lb			
Bottom Balance Size (C-F)	55RD			
Bottom Balance Size (Spring)	27.5R			
Egress Opening Width	25.0940			
Egress Opening Height	22.0525			
Egress Opening Area (sq. ft.)	3.8480			

\*

↑

\* 25.8 x 54.75 = 1413 = 144 = 9.8 sq ft

May, 20, 2011 2:07PM St Paul-Ramsey Co. Public Health