



APPLICATION FOR APPEAL

RECEIVED
AUG 08 2011
CITY CLERK

RECEIVED
AUG 08 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 8-23-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Sent 8-8-11

Address Being Appealed:

Number & Street: 919 Tuscarora Ave City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Rodger Bradford Email: gravityjunkie@yahoo.com

Phone Numbers: Business na Residence na Cell 651.249.9239

Signature: *Rodger Bradford* Date: 7-21-11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 2608 Edwards Ave, El Cerrito, CA 94530

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

One of my upstairs bedrooms is 25'w x 30'h so it meets the operable height/width, but not total sq. footage. Still height is 40", I would like to request A VARIANCE. Thank you

Rodger Bradford



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

June 3, 2011

RODGER A BRADFORD
2608 Edwards Ave
El Cerrito CA 94530-1425

FIRE INSPECTION CORRECTION NOTICE

RE: 919 TUSCARORA AVE
Residential Class: C

Dear Property Representative:

Your building was re-inspected on June 3, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on July 5, 2011 at 10:00 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Second floor south - Crank out windows - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
40.5 h x 18.5 w Glazed 5.5 sq ft
2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

An Equal Opportunity Employer

3. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
4. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. **This work requires a permit(s).** Call DSI at (651) 266-8989.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector