



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
OCT 22 2010
CITY CLERK

Tuesday,
11/02/2010
1:30 P.M.
Room 330

1. Address of Property being Appealed: <u>558 Ottawa</u>	2. Number of Dwelling Units: <u>1</u>	3. Date of Letter Appealed:
---	--	-----------------------------

4. Name of Owner: Josh Cook Jennifer Klein

Address: 558 Ottawa City: St. Paul State: MN Zip: 55107

Phone Numbers: Business 651-329-4815 Residence _____ Cellular ^{Josh} 651-767-2861

Signature: [Signature]

5. Appellant / Applicant (if other than owner): A Pane In the Glass Const. (Allen)

Address: 452 W Horseshoe City: St. Paul State: MN Zip: 55126

Phone Numbers: Business _____ Residence _____ Cellular 651-329-4815

Signature: [Signature]

6 State specifically what is being appealed and why (Use an attachment if necessary):

Variance on egress bedroom windows, they do not reach the 24" height but have a 22" height and 25.4" width

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>10/22/2010</u>	Fee Received: <u>\$ 25.00</u>	Receipt Number: <u>337964</u>	Date of Hearing: <u>11/02/2010 1:30 P.M.</u>
-------------------------------------	----------------------------------	----------------------------------	---



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 6, 2010

APPEAL PROPERTY ADDRESS: 558 OTTAWA AVE

APPLICANT NAME: A PANE IN THE GLASS CONSTRUCTION LLC

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 906763

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area	9.9 sq. ft.	Difference from Required Area	+ 4.9 sq. ft.
Width of Opening	25.4 "	Difference from Required Opening	+ 5.4 "
Height of Opening	22 "	Difference from Required Opening	- 2 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.