



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 12/21/10

APPEAL PROPERTY ADDRESS: 775 SHERBURNE AVE

APPLICANT NAME: ST PAUL & RAMSEY CO PUBLIC HEALTH PHONE NUMBER: 651-266-1145 DANIEL

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 9.08 ft²

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 23.21

DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 22.06

DIFFERENCE FROM REQUIRED OPENING: 1.94"

HEIGHT OF OPENING TO FINISHED FLOOR: 48"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

(Model 0201)	
Excalibur Double Hung	
Top Sash Width	24.3750
Top Sash Height	27.2500
Bottom Sash Width	25.3750
Bottom Sash Height	28.2500
Top Glass Width	22.8875
Top Glass Height	25.8825
Bottom Glass Width	23.8875
Bottom Glass Height	26.8825
Screen Width	23.9375
Screen Height	54.7500
Top Sash Weight (Plus 5 lb)	21 lb
Top Balance Size (C.F)	58BU
Top Balance Size (Spiral)	23-8R
Bottom Sash Weight	17 lb
Bottom Balance Size (C.F)	9NAT
Bottom Balance Size (Spiral)	41-7R
Egress Opening Width	23.2190
Egress Opening Height	27.0825
Egress Opening Area (sq.ft.)	3.5570

* TOTAL GLAZED AREA

Min. W. 13	Max. W. 53
Min. H. 22	Max. H. 64
Exact Size	
Width: 27.625	27.625
Height: 57.625	57.625
Extrusion: Select Extrusion	<< For Arch-Top Models Only
Opening: Exact Size	
Type: Standard	
Screen: Full	
Glass: Double Strength (3 mm)	

AC Sash Calculator

* $23.9 \times 54.75 = 1,309 \div 144 = 9.08 \text{ sq ft}$



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 12/21/10

APPEAL PROPERTY ADDRESS: 775 SHERBURNE AVE

APPLICANT NAME: SAINT PAUL RAMSEY CO PUBLIC HEALTH PHONE NUMBER: 651-266-1143 (DANA)

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 7.13 ft²

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 19.59"

DIFFERENCE FROM REQUIRED OPENING: .4"

HEIGHT OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING TO FINISHED FLOOR: < 48"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

(Model 0201)	
0201	
Excalibur Double Hung	
Top Sash Width	20.7500
Top Sash Height	25.1875
Bottom Sash Width	21.7500
Bottom Sash Height	25.1875
Top Glass Width	19.0625
Top Glass Height	23.5000
Bottom Glass Width	20.0625
Bottom Glass Height	24.5000
Screen Width	20.3125
Screen Height	50.6250
Top Sash Weight (Plus 6 lb)	17 lb
Top Balance Size (C.F)	9NA1
Top Balance Size (Spral)	21-7R
Bottom Sash Weight	14 lb
Bottom Balance Size (C.F)	7GN
Bottom Balance Size (Spral)	25-5R
Egress Opening Width	19.5940
Egress Opening Height	20.0000
Egress Opening Area (sq.ft.)	2.7210

*

TOTAL GLAZED AREA

Min. W. 14	Max. W. 42
Min. H. 27	Max. H. 54
Exact Size	
Width: 24	24
Height: 53.5	53.5
Extrusion: Select Extrusion	<< For Arch-Top Models Only
Opening: Exact Size	
Type: Standard	
Screen: Full	
Glass: Double Strength (3 mm)	

AC Sash Calculator

* $20.31 \times 50.62 = 1028 \div 144 = 7.13 \text{ sq ft}$