

Scanned



# APPLICATION FOR APPEAL

RECEIVED  
MAY 03 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>MAY 8, 2012</u>
Time <u>1:30 pm</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 1386 Schlett: St City: St Paul State: MO Zip: \_\_\_\_\_

Appellant/Applicant: The Window Store HI Email Michelle@homesoreinc.com

Phone Numbers: Business 612 353-5780 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: Derek Fambury Date: 5-3-12

Name of Owner (if other than Appellant): Brandon Imsdale

Address (if not Appellant's): 1386 Schlett: St

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651 492-0818

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Brandon doesn't want  
casement windows because  
they do not go with  
the character of his  
old house

STAMP has Imsdahl - rrr



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: April 25, 2012

APPEAL PROPERTY ADDRESS: 1386 SCHLETTI ST  
APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC  
PHONE NUMBER: 612-353-5780  
PERMIT NUMBER: 12 048835  
TYPE OF WINDOW Double Hung  
NUMBER OF WINDOWS 2

<b>Total Glazed Area</b> Minimum 5 Square Feet	3.7	<b>Difference from Required Area</b>	-1.3
<b>Width of Opening</b> Minimum 20 Inches	27	<b>Difference from Required Opening</b>	+7
<b>Height of Opening</b> Minimum 24 Inches	19	<b>Difference from Required Opening</b>	-5
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	OK

COMMENTS: N/A

Reviewed by: J Hoffman 4-25-12