

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 10/25/10

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To FAX#: 6-8574

RECEIVED
OCT 25 2010
CITY CLERK

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Bruce Noyes / Jim Hannorelly
St. Paul-Ramsey Cty. Dept. of Public Health

This transmission consists of 3 pages (including cover sheet)

If transmission is incomplete or illegible, call sender at (651) 266-1172 (Bruce Noyes)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

WINDOW SPECS

2 Bedrooms, 2 windows, SAME SIZE

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM



EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/25

APPEAL PROPERTY ADDRESS: 1258 MARION

APPLICANT NAME: ST PAUL & RAMSEY CO. PHONE NUMBER: 266-1138
OWNER: Matthew Jefferson

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.3 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLES

WIDTH OF OPENING: 23" DIFFERENCE FROM REQUIRED OPENING: COMPLES

HEIGHT OF OPENING: 19.9" DIFFERENCE FROM REQUIRED OPENING: 4.1"


HEIGHT OF OPENING
OF FINISHED FLOOR: 2 4/8" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLES

RECOMMENDATION (IF APPLICABLE): _____

St Paul-Ramsey Co. Public Health

Oct. 25. 2010 12:15PM

FROM: _____



Select a Model

(Model 0201)
Excelsior Double Hung

Top Sash Width	24.2500
Top Sash Height	26.1250
Bottom Sash Width	25.1250
Bottom Sash Height	28.1250
Top Glass Width	22.9625
Top Glass Height	22.9625
Bottom Glass Width	23.9625
Bottom Glass Height	22.9625
Screen Width	23.5125
Screen Height	26.6100
Top Sash Weight (plus 5 lbs)	20 lb
Bottom Sash Weight	55 lb
Top Balance Size (Spring)	21.718
Bottom Balance Size (Spring)	18.718
Bottom Balance Size (C.H.)	8.0
Bottom Balance Size (Spiral)	23.0440
Glass Opening Width	23.0440
Glass Opening Height	19.8125
Figure Opening Area (sq.ft.)	3.1970

** Total Sash Area*

Exact Size: 27.5 (Width) x 27.5 (Height)

WALK: 27.5
HIGHT: 27.5

Estimate: Select Estimate
Opening: Exact Size
Type: Standard
Screen: Full
Glass: Double Strength (3 mm)

AC Sash Operation
A Designated AC Sash & Inserts Require BOTH Top and Bottom Sashes When AC is in the Window

AC Width:
AC Height:

* 23.8 x 50.5 = 1201.9 ÷ 144 = 8.3 sq ft.