



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 19, 2011

George Tremberlak
JB Construction of St Paul
obo Dan/Mark Properties/TCM
P O Box 7883
St Paul MN 55107

Re: Appeal for property at 799 Park Street
File ID: ALH 11-58

Dear Mr. Tremberlak:

This is to confirm that on January 10, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 3.5-inch variance on the openable height of one double hung replacement egress bedroom window in the 3rd floor which measured at 20.5 inches high by 26.5 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File

