

Other

OtherOther

APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED

SEP 1 7 2010

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to prospect to the City of States and States are being appealed Attachments you may wish to include This appeal form completed	Saint Paul Tuesday, $9/28/10$ ter which Time $1:30$
Address Being Appealed:	
Number & Street: 1657 Mu	mehana City: St. Paul State: MN Zip: 55 10 C
	Email howk_cu@yahoo.com
Phone Numbers: Business	Residence Cell
Signature:	Date: 9-17-2010
Name of Owner (if other than Appellant):	
Address (if not Appellant's):	
Phone Numbers: Business	Residence Cell
What Is Being appealed and why? Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O	Deficiency list #3#6
□ Summary/Vehicle Abatement	I have Strip off all the pealed paint and pointed
Fire C of O Deficiency List	over twice already. Inspector James Thomas
☐ Fire C of O: Only Egress Windows	disagree with my work. I would like to
□ Code Enforcement Correction Notice	delay #3,4900 next seemmer while while
□ Vacant Building Registration	I complete the vest of the deliciency list.



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

Web: www.stpaul.gov/dsi

September 8, 2010

HANK CU 1119 RIVER PKWY MINNEAPOLIS MN 55414

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 1657 MINNEHAHA AVE E

Ref. # 15849

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on September 8, 2010. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on September 21, 2010 at 11:45 A.M.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. Unit 2 SPLC 34.10 (7), 34.33 (6) Repair and maintain the ceiling in an approved manner.-Repair or replace the damaged or deteriorated ceiling.

 Paint the ceiling. Bathroom
- 2. Unit 2 UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. The entire exhaust system shall be supported and secured in place. Installation requires a permit.
- 3. SPLC 34.09 (1) b,c, 34.32 (1) b,c Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.
- 4. SPLC 34.09 (3), 34.32 (3) Provide or repair and maintain the window screens.



- 5. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 6. SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, GARAGE and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector Ref. # 15849