



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 4, 2011

Bryan Horton
Renewal by Andersen Corporation
obo Jennifer Davis-Lammers
1920 County Rd C W
Roseville MN 55113

VIA EMAIL: bryan.horton@andersencorp.com

Re: Appeal for property at 426 Mt Curve Rd
File ID: ALH 11-228

Dear Mr. Horton:

This is to confirm that on February 3, 2011, Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 3-inch variance on the openable width of one casement replacement egress bedroom window which measured at 40.5 inches high by 17 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
File

