

✓ Scanned



# APPLICATION FOR APPEAL

RECEIVED

AUG 12 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul - call for CC# (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed - NONE sec notes below.
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 9-6-11

Time 1:30

**Location of Hearing:**

Room 330 City Hall/Courthouse

walk in

## Address Being Appealed:

1935 Old Hudson, 1949 Old Hudson Rd,

Number & Street: 365 Luella St N City: St. Paul State: MN Zip: \_\_\_\_\_

Appellant/Applicant: Joe Bockoven / JWB Const. Email bockoven@Frontiernet.net

Phone Numbers: Business 763-464-1851 Residence \_\_\_\_\_ Cell 763-464-1851

Signature: [Handwritten Signature] Date: 8-12-11

Name of Owner (if other than Appellant): Carew Properties

Address (if not Appellant's): 9100 W Bloomington Freeway Ste. 147

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 952-232-8821

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/ Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Replacing windows of same size,  
full frame replacement. 76 windows to  
be replaced, 21 are in bedrooms and do  
not meet egress. Some windows of same  
size were installed last year in other  
units, want to match those.  
DO NOT have denial on permit, was issued  
online mistakenly. Dave Nelson instructed me  
to file appeal.

Revised 8/20/2010



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: August 12, 2011

APPEAL PROPERTY ADDRESS: 1949 OLD HUDSON ROAD

APPLICANT NAME: JWB CONSTRUCTION

PHONE NUMBER: 763-464-1851

PERMIT NUMBER: 11 262472

TYPE OF WINDOW 20

NUMBER OF WINDOWS Sliders

<b>Total Glazed Area</b> Minimum 5 Square Feet	11.375	<b>Difference from Required Area</b>	+5.675
<b>Width of Opening</b> Minimum 20 Inches	18.85"	<b>Difference from Required Opening</b>	-1.15
<b>Height of Opening</b> Minimum 24 Inches	40.144	<b>Difference from Required Opening</b>	+16.14
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	44.75	<b>Difference from Maximum Height</b>	+3.25

COMMENTS:

Reviewed by: DD 8-12-11