



APPLICATION FOR APPEAL

RECEIVED
FEB 22 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 90530)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>March 6, 2012</u>
Time <u>1:30 p.m.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1014 Army Strong Ave City: St. Paul State: MN Zip: _____

Appellant/Applicant: Nelson Capital LLC Email Thomas.Rodriguez@live.com

Phone Numbers: Business _____ Residence _____ Cell 612 644 9812

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

February 6, 2012

ERIC MARTIN & ASSOCIATES
8936 SPRINGWOOD CIRCL
WOODBURY MN 55125

FIRE INSPECTION CORRECTION NOTICE

RE: 1014 ARMSTRONG AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on February 3, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on February 29, 2012 at 10:30 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Back door - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door frame.
2. Door to basement - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the floor coverings.
3. Double hung windows - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s).

An Equal Opportunity Employer

Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-

North

20 h x 32 w Glazed 9.4 sq ft

South

20 h x 32 w Glazed 9.4 sq ft

4. Exterior - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair fence where damaged.
5. North bedroom - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door frame.
6. Rear hallway - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Patch the holes and/or cracks in the walls.
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
8. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector